



COVER ASSEMBLY DTL.

NOTE: 1) HYDRO @ 165 PSIG. MIN.
2) INSPECTION OPENING, UG 46(f)(6).

SHELL / HEADS	.182" SA-455 2:1 S.E.	BB-317-L	REV.
	JOGGLE		DATE: 4-1-05
INSIDE:	UNPAINTED	HANSON STANDARD	
		VERT. BLADDER TANK	
M.A.W.P.	125 PSIG. @ 240 °F	LEG-ZONE 4-15 KM.	
M.D.M.T.	32 °F @ 125 PSIG.	OUTSIDE: PRIMER	
ASME. SECTION	VIII DIV. 1, 2004 ADD. 2004	BY: E.S. SCALE: 3/4"=12"	
X-RAY:	RT-NO	ROY E. HANSON JR. MFG.	
GALLONS:	317	WT. 636 LBS.	1924 COMPTON AVE.
SERIAL NO.			LOS ANGELES, CA 90011
N.B.			

