



**COVER ASSEMBLY DTL.**

NOTE: 1) HYDRO @ 165 PSIG. MIN.  
2) INSPECTION OPENING, UG 46(f)(6).

SHELL / HEADS	.182" SA-455 2:1 S.E.	BB-370-L	REV.
	JOGGLE		DATE: 4-1-05
	.164" SA-414-G	HANSON STANDARD	
		VERT. BLADDER TANK	
		INSIDE: UNPAINTED	
M.A.W.P.	125 PSIG. @ 240 °F	OUTSIDE: PRIMER	
M.D.M.T.	32 °F @ 125 PSIG.	LEG-ZONE 4-15 KM.	
ASME. SECTION VIII DIV. 1, 2004 ADD. 2004		BY: E.S. SCALE: 3/4"=12"	
X-RAY:	RT-NO	<b>ROY E. HANSON JR. MFG.</b>	
GALLONS:	370	1924 COMPTON AVE.	
SERIAL NO.	WT. 707 LBS.	LOS ANGELES, CA 90011	
N.B.			

