



NOTE: 1) HYDRO @ 166 PSIG. MIN.
 2) WELD 3/4"Ø ROUND BARS TO SHELL AFTER HEADS ARE IN PLACE.

SHELL / HEADS	.248" SA-455 2:1 S.E.	WL-633-B	REV. 9-12-06
			DATE: 8-23-06
		FOR:	
	.250" SA-455	VERT. CHILLED WATER TANK	
		INSIDE: NONE	
M.A.W.P.	125 PSIG. @ 200 °F	OUTSIDE: PRIME	
M.D.M.T.	0 °F 125 PSIG	SEISMIC ZONE: 2-B	
ASME. SECTION VIII	DIV. 1, 2004 ADD 2005	BY: J.G./STEVE	SCALE: 1/2"=12"
X-RAY:	RT-4 SPOT L.S. & HDS. G.S.	ROY E. HANSON JR. MFG.	
GALLONS:	1650	1600 E. WASHINGTON BLVD.	
SERIAL NO.		LOS ANGELES, CA 90021	
N.B.			