



2"R W/ C.I. PLUG FOR INSPECTION OPENING (2) PLC'S.

4"-150# R.F.S.O. FLG. W/SCH 40 PIPE x 7 1/16"LG. (2) PLC'S

.135"THK. BAFFLE PER: WL-632-B-1A

3/4"Ø ROUND BAR SA-36 x 6"LG. (4) PLC'S. SEE NOTE: 2

3/16"THK. CLIPS PER MA-395-B (4) PLC'S. W/ 9/16"Ø HOLE ON 20 3/8"B.C.; WELD OUTSIDE VERT. EDGE OF CLIP ONLY

NOTE: 1) HYDRO @ 197 PSIG. MIN. 2) WELD 3/4"Ø ROUND BARS TO SHELL AFTER HEADS ARE IN PLACE.

SHELL / HEADS	
JOGGLE	.164" SA-414-G 2:1 S.E.
	.135" SA-414-G
M.A.W.P.	150 PSIG. @ 200 °F
M.D.M.T.	0 °F @ 150 PSIG.
ASME SECTION VIII	DIV. 1, 2007 ADD 2007
X-RAY:	RT-NO
GALLONS:	120 WT. 368 LBS.
SERIAL NO.	
N.B.	
WL-695-B	
FOR: -	REV. 7-17-08
VERT. CHILLED WATER TANK	DATE: 10-18-06
SURFACE AREA = 35.9 SQ. FT.	
INSIDE: UNPAINTED	
OUTSIDE: SHOP PRIME	
BY: J.G. / C.J.	SCALE: 1"=12"
ROY E. HANSON JR. MFG.	
1600 E. WASHINGTON BLVD.	
LOS ANGELES, CA 90021	