



.135" THK. BAFFLE  
 PER: WL-264-B-1A

2) WELD 3/4"  $\phi$  ROUND BARS TO SHELL AFTER HEADS ARE IN PLACE.  
 NOTE: 1) HYDRO @ 195 PSIG. MIN.

SHELL / HEADS	.140" SA-414-G 2:1 S.E.
	JOGGLE
	.165" SA-414-G
M.A.W.P.	150 PSIG. @ 200 °F
M.D.M.T.	0 °F @ 150 PSIG.
ASME. SECTION VIII DIV. 1, 2007 ADD 2008	
X-RAY:	RT-NO
GALLONS:	200
WT.	438 LBS.
SERIAL NO.	
N.B.	

<b>WL-786-B</b>		REV. 4-13-09
		DATE: 1-15-07
FOR: .		
VERT. CHILLED WATER TANK		
INSIDE: UNPAINTED		
OUTSIDE: SHOP PRIME		
BY: J.G. / B.C.	SCALE: 1"=12"	
<b>ROY E. HANSON JR. MFG.</b>		
1600 E. WASHINGTON BLVD. LOS ANGELES, CA 90021		