



NOTE: 1) HYDRO @ 165 PSIG. MIN.
 2) WELD 3/4" ϕ ROUND BARS TO SHELL AFTER HEADS ARE IN PLACE.

SHELL / HEADS	.200" SA-455 2:1 S.E.	WM-199-B	REV.
	JOGGLED - .208 OFFSET		DATE: 2-11-08
		FOR:	
		VERT. CHILLED WATER TANK.	
		SURFACE AREA = 126.8 SQ. FT.	
		INSIDE: UNPAINTED	
		OUTSIDE: PRIME	
M.A.W.P.	125 PSIG. @ 200 °F	BY: J.G./B.C.	SCALE: 3/4" = 12"
M.D.M.T.	0 °F @ 125 PSIG.	ROY E. HANSON JR. MFG.	
ASME. SECTION	VIII DIV. 1, 2007 ADD 2007	1600 E. WASHINGTON BLVD.	
X-RAY:	RT-4 SPOT L.S. ONLY	LOS ANGELES, CA 90021	
GALLONS:	800	WT.	1476 LBS.
SERIAL NO.			
N.B.			