



VIEW W/OUT SUPT'S

2) WELD 3/4"φ ROUND BARS TO SHELL AFTER HEADS ARE IN PLACE.
 NOTE: 1) HYDRO @ 164 PSIG. MIN.

| | | | |
|--|-------------------------|--------------------------------|---------------|
| HEADS | .166" SA-414-G 2:1 S.E. | WM-249-B | REV. |
| | JOGGLE | | DATE: 3-26-08 |
| SHELL | .165" SA-414-G | FOR: - | |
| | | HORIZ. CHILLED WATER TANK | |
| | | SURFACE AREA = 73.0 SQ. FT. | |
| | | INSIDE: UNPAINTED | |
| M.A.W.P. 125 PSIG. @ 200 °F | | OUTSIDE: SAND BLAST | |
| M.D.M.T. 0 °F @ 125 PSIG. | | | |
| ASME. SECTION VIII DIV. 1, 2007 ADD 2007 | | | |
| X-RAY: RT-NO | | BY: J.G./STEVE SCALE: 1"=12" | |
| GALLONS: 300 WT. 627 LBS. | | ROY E. HANSON JR. MFG. | |
| SERIAL NO. | | 1600 E. WASHINGTON BLVD. | |
| N.B. | | LOS ANGELES, CA 90021 | |