



- 4) 3-19-09 PROOF TEST.
- 3) EXTEND ALL CPLGS. 5/8" INSIDE.
- 2) HYDRO @ 240 PSIG.
- NOTE: 1) SEAL ALL OPENINGS TO KEEP CEMENT MOIST TO PREVENT CRACKING.

| | | | |
|--|--|-----------------------|--|
| SHELL / HEADS | | .205" SA-455 2:1 S.E. | |
| JOGGLE | | | |
| .175" SA-414-G | | | |
| M.A.W.P. 160 PSIG. @ 210 °F | | | |
| ASME SECTION IV 2010 ADD 2010 | | | |
| X-RAY: RT-NO / H.L.W. | | | |
| GALLONS: 534 | | WT. 1583 LBS. | |
| SERIAL NO. | | | |
| N.B. | | | |
| FOR: HANSON STANDARD | | REV. 6-14-11 | |
| HORIZ. HOT WATER TANK | | DATE: 7-23-91 | |
| 94.1 SQ. FT. SURFACE AREA. | | | |
| THIS TANK IS SHIPPED WITH ALL OPENINGS SEALED. THE CEMENT LINING MUST BE KEPT MOIST BEFORE, DURING, AND AFTER INSTALLATION TO PREVENT CRACKING OF THE CEMENT | | | |
| INSIDE: CEMENT LINED | | | |
| OUTSIDE: PRIME | | | |
| CAD "B" SIZE UNDER "STD"-SERIES | | | |
| BY: E.S. | | SCALE: 3/4"=12" | |
| ROY E. HANSON JR. MFG. | | | |
| 1600 E. WASHINGTON BLVD. | | | |
| LOS ANGELES, CA 90021 | | | |

VIEW W/O SUPPORTS