



VIEW W/O SUPPORTS

- NOTE: 1) SEAL ALL OPENINGS TO KEEP CEMENT MOIST TO PREVENT CRACKING.
- 2) HYDRO @ 240 PSIG.
 - 3) EXTEND ALL CPLGS. 5/8" INSIDE.
 - 4) 3-19-09 PROOF TEST.

SHELL / HEADS		M.A.W.P. 160 PSIG. @ 210 °F	
.175" SA-414-G		ASME. SECTION IV 2010 ADD 2010	
JOGGLE		X-RAY: RT-NO / H.L.W.	
.205" SA-455 2:1 S.E.		GALLONS: 600 WT. 1752 LBS.	
SOLAR FEET PER: S-42-660-H-1C		SERIAL NO.	
FOR: HANSON STANDARD		N.B.	
HORIZ. HOT WATER TANK		REV. 6-13-11	
105.4 SQ. FT. SURFACE AREA.		DATE: 10-2-89	
THIS TANK IS SHIPPED WITH ALL OPENINGS SEALED. THE CEMENT LINING MUST BE KEPT MOIST BEFORE, DURING, AND AFTER INSTALLATION TO PREVENT CRACKING OF THE CEMENT		CS-42-600-H	
INSIDE: CEMENT LINED		REV. 6-13-11	
OUTSIDE: PRIME		DATE: 10-2-89	
CAD "B" SIZE UNDER "STD"-SERIES		FOR: HANSON STANDARD	
BY: E.S. SCALE: 3/4"=12"		HORIZ. HOT WATER TANK	
ROY E. HANSON JR. MFG.		105.4 SQ. FT. SURFACE AREA.	
1600 E. WASHINGTON BLVD.		THIS TANK IS SHIPPED WITH ALL OPENINGS SEALED. THE CEMENT LINING MUST BE KEPT MOIST BEFORE, DURING, AND AFTER INSTALLATION TO PREVENT CRACKING OF THE CEMENT	
LOS ANGELES, CA 90021		INSIDE: CEMENT LINED	