



VIEW W/O SUPPORTS

- NOTE: 1) SEAL ALL OPENINGS TO KEEP CEMENT MOIST TO PREVENT CRACKING.
- 2) HYDRO @ 240 PSIG.
 - 3) EXTEND ALL CPLGS. 5/8" INSIDE.
 - 4) 3-19-09 PROOF TEST.

SHELL / HEADS		.205" SA-455 2:1 S.E.	
JOGGLE			
.175" SA-414-G			
M.A.W.P. 160 PSIG. @ 210 °F			
ASME SECTION IV 2010 ADD 2010			
X-RAY: RT-NO / H.L.W.			
GALLONS: 660 WT. 1907 LBS.			
SERIAL NO.			
N.B.			
CS-42-660-H		REV. 6-14-11	
FOR: HANSON STANDARD		DATE: 7-15-02	
HORIZ. HOT WATER TANK			
115.8 SQ. FT. SURFACE AREA.			
THIS TANK IS SHIPPED WITH ALL OPENINGS SEALED. THE CEMENT LINING MUST BE KEPT MOIST BEFORE, DURING, AND AFTER INSTALLATION TO PREVENT CRACKING OF THE CEMENT			
INSIDE: CEMENT LINED			
OUTSIDE: PRIME			
CAD "B" SIZE UNDER "STD"-SERIES			
BY: E.S.		SCALE: 3/4"=12"	
ROY E. HANSON JR. MFG.			
1600 E. WASHINGTON BLVD.			
LOS ANGELES, CA 90021			