



VIEW W/OUT SUPPORTS

3) EXTEND ALL CPLGS. 5/8" INSIDE.
 2) HYDRO @ 188 PSIG. MIN. TO 197 PSIG. MAX.
 NOTE: 1) SEAL ALL OPENINGS TO KEEP CEMENT MOIST TO PREVENT CRACKING.

HEADS	LEFT-.248" SA-455 2:1 S.E.	CS-64-1650-H	REV. 9-4-07
	(.212" MIN.)		DATE: 10-23-89
	RIGHT-.289" SA-455 2:1 S.E.	FOR: HANSON STANDARD	
	(.235" MIN.)	HORIZ. WATER TANK	
SHELL	.250" SA-455	197.0 SQ. FT. SURFACE AREA. THIS TANK IS SHIPPED WITH ALL OPENINGS SEALED. THE CEMENT LINING MUST BE KEPT MOIST BEFORE, DURING, AND AFTER INSTALLATION TO PREVENT CRACKING OF THE CEMENT.	
	M.A.W.P. 125 PSIG. @ 210 °F	INSIDE: CEMENT LINED (1583)	
ASME. SECTION IV 2004 ADD. 2006		OUTSIDE: PRIME	
X-RAY: RT-NO / H.L.W.		CAD-"B" UNDER "STD"-SERIES	
GALLONS: 1650 WT. 3800 LBS.		BY: J.G.	SCALE: 1/2"=12"
SERIAL NO.		ROY E. HANSON JR. MFG.	
N.B.		1600 E. WASHINGTON BLVD. LOS ANGELES, CA 90021	