



NOTE: 1) HYDRO @ 240 PSIG. MIN.  
 2) 4-1-04 PROOF TEST.

SOLAR FEET PER:  
 S-30-350-H-1C  
 NO GUSSETS

|                             |                         |
|-----------------------------|-------------------------|
| SHELL / HEADS               | .166" SA-414-G 2:1 S.E. |
| JOGGLE                      |                         |
|                             | .165" SA-414-G          |
| M.A.W.P.                    | 160 PSIG. @ 180 °F      |
| ASME SECTION                | IV 2007 ADD 2009        |
| X-RAY:                      | RT-NO / H.L.W.          |
| GALLONS:                    | 270 WT. 543 LBS.        |
| SERIAL NO.                  |                         |
| N.B.                        |                         |
| ES-30-270-H                 | REV. 6-28-10            |
|                             | DATE: 3-2-90            |
| FOR: HANSON STANDARD        |                         |
| HORIZ. HOT WATER TANK       |                         |
| SURFACE AREA = 66.3 SQ. FT. |                         |
| INSIDE: EPOXY LINED         |                         |
| OUTSIDE: PRIME              |                         |
| CAD-"B" UNDER "STD"-SERIES  |                         |
| BY: E.S.                    | SCALE: 1"=12"           |

VIEW W/OUT SUPPORTS

|                               |  |
|-------------------------------|--|
| <b>ROY E. HANSON JR. MFG.</b> |  |
| 1600 E. WASHINGTON BLVD.      |  |
| LOS ANGELES, CA 90021         |  |