



- NOTE: 1) SEAL ALL OPENINGS TO KEEP CEMENT MOIST TO PREVENT CRACKING.
- 2) INSTALL (3) 1 5/16" x 30" RIGID MAG. ANODES, BEFORE FG & MJ.
 - 3) HYDRO @ 188 PSIG. MIN. TO 197 PSIG. MAX.
 - 4) EXTEND ALL CPLG'S 5/8" MIN. INSIDE.
 - 5) PIPES SA-312-304 ERW S.S.

SHELL / HEADS		.250" SA-414-G 2:1 S.E.	
JOGGLE			
		.200" SA-455	
M.A.W.P.		125 PSIG. @ 210 °F	
ASME SECTION IV		2007 ADD 2008	
X-RAY:		RT-NO/H.L.W.	
GALLONS:		500	WT. 1812 LBS.
SERIAL NO.			
N.B.			
FOR: -		WM-802-B	
HORIZ. HOT WATER TANK		REV. DATE: 9-10-09	
86.1 SQ. FT. SURFACE AREA.			
THIS TANK IS SHIPPED WITH ALL OPENINGS SEALED. THE CEMENT LINING MUST BE KEPT MOIST BEFORE, DURING, AND AFTER INSTALLATION TO PREVENT CRACKING OF THE CEMENT.			
INSIDE: CEMENT LINED			
OUTSIDE: PRIME AND 2" FIBERGLASS WITH ALUMINUM JACKET			
BY: J.G./C.J.		SCALE: 3/4"=12"	
ROY E. HANSON JR. MFG.			
1600 E. WASHINGTON BLVD.			
LOS ANGELES, CA 90021			