



VIEW W/O SUPPORTS

- 3) 4-1-04 PROOF TEST.
- 2) HYDRO @ 240 PSIG. MIN.

NOTE: 1) INSTALL (2) 1 5/16"x 24" LG. RIGID MAG. ANODES.

HEADS	.189" SA-414-G 2:1 S.E.	GS-36-335-H	REV. 9-4-13
	JOGGLE		DATE: 12-21-02
SHELL	.166" SA-414-G	FOR: HANSON STANDARD	
		HORIZ. HOT WATER TANK	
		SURFACE AREA = 70.6 SQ. FT.	
		INSIDE: GLASS LINED	
	M.A.W.P. 160 PSIG. @ 210 °F	OUTSIDE: S. BLAST & PRIME	
	ASME SECTION IV 2010 ADD. 2011	CAD-"B" UNDER "STD"-SERIES	
	X-RAY: RT-NO / H.L.W.	BY: E.S.	SCALE: 3/4"=12"
	GALLONS: 335	WT. 685 LBS.	ROY E. HANSON JR. MFG.
	SERIAL NO.	1600 E. WASHINGTON BLVD.	
	N.B.	LOS ANGELES, CA 90021	