



NOTE: 1) SEAL ALL OPENINGS TO KEEP CEMENT MOIST TO PREVENT CRACKING.  
 2) EXTEND ALL CPLGS. 5/8" INSIDE.  
 3) HYDRO @ 240 PSIG. MIN.  
 4) 4-1-04 PROOF TEST.

HEADS / SHELL	.182" SA-455 2:1 S.E.	CS-36-305-V	REV. 1-11-07
	JOGGLE - .149 OFFSET		DATE: 2-27-92
SHELL / HEADS	.165" SA-414-G	FOR: HANSON STANDARD VERT. HOT WATER TANK	
	M.A.W.P. 160 PSIG. @ 210 °F	65.2 SQ. FT. SURFACE AREA. THIS TANK IS SHIPPED WITH ALL OPENINGS SEALED. THE CEMENT LINING MUST BE KEPT MOIST BEFORE, DURING, AND AFTER INSTALLATION TO PREVENT CRACKING OF THE CEMENT.	
ASME. SECTION IV 2004 ADD 2006	X-RAY: RT-NO / H.L.W.	INSIDE: CEMENT LINED	
GALLONS: 305	WT. 1023 LBS.	OUTSIDE: PRIME	
SERIAL NO.	N.B.	(289) LEG-ZONE 4-15 KM.	
		CAD-"B" UNDER "STD"-SERIES	
		BY: E.S.	SCALE: 1"=12"
		<b>ROY E. HANSON JR. MFG.</b>	
		1600 E. WASHINGTON BLVD. LOS ANGELES, CA 90021	