



NOTE. 1) SEAL ALL OPENINGS TO KEEP CEMENT MOIST TO PREVENT CRACKING.  
 2) HYDRO @ 240 PSIG.  
 3) EXTEND ALL CPLG'S 5/8" INSIDE.  
 4) 4-1-04 PROOF TEST.

SHELL / HEADS	.205" SA-455 2:1 S.E.	CS-42-534-V	REV. 1-19-07
	JOGGLE		DATE: 5-29-96
SHELL / HEADS	.189 OFFSET - BROWN STRIPE	FOR: HANSON STANDARD	
	.175" SA-414-G	VERT. HOT WATER TANK	
M.A.W.P.	160 PSIG. @ 210 °F	94.4 SQ. FT. SURFACE AREA.	
ASME. SECTION IV	2004 ADD 2006	THIS TANK IS SHIPPED WITH ALL OPENINGS SEALED. THE CEMENT LINING MUST BE KEPT MOIST BEFORE, DURING, AND AFTER INSTALLATION TO PREVENT CRACKING OF THE CEMENT.	
X-RAY:	RT-NO / H.L.W.	INSIDE: CEMENT LINED	
GALLONS:	534	WT. 1558 LBS.	OUTSIDE: PRIME
SERIAL NO.			(498) LEG-ZONE 4-15 KM.
N.B.			CAD "B" UNDER "STD"-SERIES
			BY: J.G. SCALE: 3/4"=12"
			<b>ROY E. HANSON JR. MFG.</b>
			1600 E. WASHINGTON BLVD. LOS ANGELES, CA 90021