



NOTE. 1) SEAL ALL OPENINGS TO KEEP CEMENT MOIST TO PREVENT CRACKING.  
 2) HYDRO @ 240 PSIG.  
 3) EXTEND ALL CPLG'S 5/8" INSIDE.  
 4) 4-1-04 PROOF TEST.

SHELL / HEADS	.205" SA-455 2:1 S.E.	CS-42-660-V	REV. 1-22-07
	JOGGLE		DATE: 5-21-96
	.189 OFFSET - BROWN STRIPE		FOR: HANSON STANDARD
	.175" SA-414-G		VERT. HOT WATER TANK
M.A.W.P. 160 PSIG. @ 210 °F		115.8 SQ. FT. SURFACE AREA.	
ASME. SECTION IV 2004 ADD 2006		THIS TANK IS SHIPPED WITH ALL OPENINGS SEALED. THE CEMENT LINING MUST BE KEPT MOIST BEFORE, DURING, AND AFTER INSTALLATION TO PREVENT CRACKING OF THE CEMENT.	
X-RAY: RT-NO / H.L.W.		INSIDE: CEMENT LINED	
GALLONS: 660	WT. 1898 LBS.	OUTSIDE: PRIME	
SERIAL NO.		(632) LEG ZONE: 4-15 KM.	
N.B.		CAD "B" UNDER "STD"-SERIES	
		BY: J.G.	SCALE: 3/4"=12"
		<b>ROY E. HANSON JR. MFG.</b>	
		1600 E. WASHINGTON BLVD. LOS ANGELES, CA 90021	