



1 1/4" - 3000#
HALF CPLG.
(2) PLC'S.

(4) 4" x 4" x 3/8" THK.
x 24 7/8" LG. ANGLE LEG

(4) 6" x 6" x 1/2" THK.
PAD W/ 3/4" Ø HOLE
FOR 1/2" Ø x 6" LG.
GRADE 5 OR BETTER

NOTE: 1) SEAL ALL OPENINGS TO KEEP CEMENT MOIST TO PREVENT CRACKING.
 2) HYDRO @ 240 PSIG. MIN.
 3) EXTEND ALL CPLGS. 5/8" INSIDE.
 4) 8-4-04 PROOF TEST.

SHELL / HEADS	.250" SA-455 2:1 S.E.
	JOGGLED
SHELL	.230" SA-455
M.A.W.P.	160 PSIG. @ 210 °F
ASME. SECTION	IV 2004 ADD. 2006
X-RAY:	RT-NO / H.L.W.
GALLONS:	1040
WT.	2813 LBS.
SERIAL NO.	
N.B.	

CS-54-1040-V	REV. 1-24-07
	DATE: 7-30-97
FOR: HANSON STANDARD VERT. HOT WATER TANK.	
146.1 SQ. FT. SURFACE AREA. THIS TANK IS SHIPPED WITH ALL OPENINGS SEALED. THE CEMENT LINING MUST BE KEPT MOIST BEFORE, DURING, AND AFTER INSTALLATION TO PREVENT CRACKING OF THE CEMENT.	
INSIDE: CEMENT LINED	
OUTSIDE: PRIME	
(993) LEG-ZONE 4-15 KM.	
CAD-"B" UNDER "STD"-SERIES	
BY: J.G.	SCALE: 3/4" = 1'
ROY E. HANSON JR. MFG.	
1600 E. WASHINGTON BLVD. LOS ANGELES, CA 90021	