



NOTE: 1) SEAL ALL OPENINGS TO KEEP CEMENT MOIST TO PREVENT CRACKING.
 2) HYDRO @ 188 PSIG. MIN. TO 197 PSIG. MAX.
 3) EXTEND ALL CPLGS. 5/8" INSIDE.

| | | | |
|-----------------|-----------------------|---|----------------------------|
| SHELL / HEADS | .248" SA-455 2:1 S.E. | CS-56-1225-V | REV. 3-17-04 |
| | (.186" MIN.) JOGGLE | | DATE: 8-30-96 |
| SHELL | .218" SA-455 | FOR: HANSON STANDARD VERT. WATER TANK | |
| M.A.W.P. | 125 PSIG. @ 210 °F | 165.7 SQ. FT. SURFACE AREA. THIS TANK IS SHIPPED WITH ALL OPENINGS SEALED. THE CEMENT LINING MUST BE KEPT MOIST BEFORE, DURING, AND AFTER INSTALLATION TO PREVENT CRACKING OF THE CEMENT. | |
| ASME SECTION IV | 2001 ADD. 2003 | INSIDE: CEMENT LINED | |
| X-RAY: | RT-NO / H.L.W. | OUTSIDE: PRIME | |
| GALLONS: | 1225 | WT. 2993 LBS. | (1180) LEG-ZONE 4-15 KM. |
| SERIAL NO. | | | CAD-"B" UNDER "STD"-SERIES |
| N.B. | | | BY: E.S. SCALE: 1/2"=12" |
| | | ROY E. HANSON JR. MFG. | |
| | | 1924 COMPTON AVE. LOS ANGELES, CA 90011 | |