



4) 5-6-04 PROOF TEST.  
 3) EXTEND ALL CPLGS. 5/8" INSIDE.  
 2) HYDRO @ 188 PSIG. MIN. TO 197 PSIG. MAX.  
 NOTE: 1) SEAL ALL OPENINGS TO KEEP CEMENT MOIST TO PREVENT CRACKING.

HEADS	.225" SA-455 2:1 S.E. (.199" MIN.)	CS-60-1450-V	REV. 9-13-04
			DATE: 3-27-03
SHELL	.218" SA-455	FOR: HANSON STANDARD VERT. HOT WATER TANK	
		185.0 SQ. FT. SURFACE AREA. THIS TANK IS SHIPPED WITH ALL OPENINGS SEALED. THE CEMENT LINING MUST BE KEPT MOIST BEFORE, DURING, AND AFTER INSTALLATION TO PREVENT CRACKING OF THE CEMENT.	
M.A.W.P.	125 PSIG. @ 210 °F	INSIDE: CEMENT LINED	
ASME SECTION	IV 2001 ADD. 2003	OUTSIDE: PRIME	
X-RAY:	RT-NO / H.L.W.	(1392) LEG-ZONE 4-15 KM.	
GALLONS:	1450	WT. 3419 LBS.	CAD-"B" UNDER "STD"-SERIES
SERIAL NO.		BY: E.S.	SCALE: 1/2"=12"
N.B.		<b>ROY E. HANSON JR. MFG.</b> 1924 COMPTON AVE. LOS ANGELES, CA 90011	