



2) 5-6-04 PROOF TEST.
 NOTE: 1) HYDRO @ 188 PSIG. MIN. TO 197 PSIG. MAX.

SHELL / HEADS	.225" SA-455 2:1 S.E. (.199" MIN.)	ES-60-1450-V	REV. 9-13-04
			DATE: 9-13-89
		FOR: HANSON STANDARD	
		VERT. HOT WATER TANK	
	.218" SA-455	SURFACE AREA = 185.0 SQ. FT.	
		INSIDE: EPOXY LINED	
		OUTSIDE: PRIME	
		LEG-ZONE 4-15 KM.	
		CAD-"B" SIZE UNDER "ES"-SERIES	
		BY: E.S.	SCALE: 1/2"=12"
		ROY E. HANSON JR. MFG.	
		1924 COMPTON AVE. LOS ANGELES, CA 90011	
M.A.W.P.	125 PSIG. @ 180 °F		
ASME. SECTION	IV 2001 ADD. 2003		
X-RAY:	RT-NO / H.L.W.		
GALLONS:	1450	WT: 2075	LBS.
SERIAL NO.			
N.B.			

