



NOTE: 1) HYDRO @ 240 PSIG.  
 2) 10-1-04 PROOF TEST.

SHELL / HEADS	.248" SA-455 2:1 S.E.
	(.216" MIN.)
SHELL	.250" SA-455
M.A.W.P.	160 PSIG. @ 180 °F
ASME. SECTION IV	2001 ADD 2003
X-RAY:	RT-NO / H.L.W.
GALLONS:	1650
WT.	2354 LBS.
SERIAL NO.	
N.B.	

ES-64-1650-V	REV: 10-6-04
	DATE: 9-22-89
FOR: HANSON STANDARD	
VERT. WATER TANK	
SURFACE AREA = 197.2 SQ. FT.	
INSIDE: EPOXY LINED	
OUTSIDE: PRIME	
LEG-ZONE 4-15 KM.	
CAD "B" SIZE UNDER "STD"-SERIES	
BY: J.G.	SCALE: 1/2"=12"
<b>ROY E. HANSON JR. MFG.</b>	
1924 COMPTON AVE. LOS ANGELES, CA 90011	