



- NOTE: 1) PROJECT: WINCHESTER BLVD., 1655, CAMPBELL.  
 2) HYDRO @ 188 PSIG. MIN. TO 197 PSIG. MAX.  
 3) 3-26-04 PROOF TEST.  
 4) SHIP LOOSE W/ (4) 1 5/16" x 48" LG. FLEX. MAG. ANODES.

HEADS	LEFT - .250" SA-455 2:1 S.E. (.228" MIN.)	RIGHT - .289" SA-455 2:1 S.E. (.252" MIN.)
SHELL	.248" SA-455	
M.A.W.P.	125 PSIG. @ 210 °F	
ASME SECTION	IV 2007 ADD 2009	
X-RAY:	RT-NO / H.L.W.	
GALLONS:	1933	WT. 3220 LBS.
SERIAL NO.	N.B.	
FOR:	WM-990-B	
HORIZ. HOT WATER TANK	REV. 7-8-10	DATE: 7-6-10
SURFACE AREA = 225.4 SQ. FT.		
INSIDE: GLASS LINED		
OUTSIDE: S. BLAST. INORGANIC		
ZINC PRIME		
BY: J.G./C.J.	SCALE: 1/2"=12"	
<b>ROY E. HANSON JR. MFG.</b>	1600 E. WASHINGTON BLVD. LOS ANGELES, CA 90021	