



NOTE: 1) 4-1-04 PROOF TEST.  
2) HYDRO @ 225 PSIG. MIN. TO 235 PSIG. MAX.

SHELL / HEADS		M.A.W.P. 150 PSIG. @ 180 °F	
.182" SA-455 2:1 S.E.		ASME SECTION IV 2004 ADD 2005	
JOGGLE		X-RAY: RT-NO / H.L.W.	
.164" SA-414-G		GALLONS: 348 WT. 734 LBS.	
SERIAL NO.		N.B.	
WK-751-B		FOR: -	
DATE: 7-20-04		VERT. HOT WATER TANK	
REV: 6-1-06		SURFACE AREA = 70.5 SQ. FT.	
INSIDE: EPOXY LINED		OUTSIDE: PRIME & R-16	
LEG-ZONE 4-2 KM.		BY: J.G. / H.D. SCALE: 3/4"=12"	
ROY E. HANSON JR. MFG.		1600 E. WASHINGTON BLVD.	
LOS ANGELES, CA 90021			