



NOTE. 1) SEAL ALL OPENINGS TO KEEP CEMENT MOIST TO PREVENT CRACKING.
 2) HYDRO @ 165 PSIG. MIN.
 3) EXTEND ALL CPLG'S 5/8" INSIDE.
 4) ALL FNPT'S SA-182-304 S.S.
 5) 8" COLLAR SA-312-304 E.R.W.
 6) NO CEMENT IN 8" COLLAR.

SHELL / HEADS	
JOGGLE	.245" SA-455 2:1 S.E.
TOP-.205"	SA-455 @ 62 3/8"
BTM-.250"	SA-455 @ 22 3/4"
LEG ZONE: 4-2 KM.	
M.A.W.P.	125 PSIG. @ 210 °F
M.D.M.T.	-20 °F @ 125 PSIG.
ASME. SECTION VIII DIV. 1, 2010 ADD 2011	
X-RAY:	RT-NO
GALLONS:	800 WT. 2087 LBS.
SERIAL NO.	
N.B.	

WN-423-B
 FOR: -
 VERT. HOT WATER TANK UW-21(b)
 126.9 SQ. FT. SURFACE AREA.
 THIS TANK IS SHIPPED WITH ALL OPENINGS SEALED. THE CEMENT LINING MUST BE KEPT MOIST BEFORE, DURING, AND AFTER INSTALLATION TO PREVENT CRACKING OF THE CEMENT.
 INSIDE: CEMENT LINED
 OUTSIDE: PRIME
 BY: E.S. / C.J. SCALE: 3/4"=12"
ROY E. HANSON JR. MFG.
 1600 E. WASHINGTON BLVD.
 LOS ANGELES, CA 90021

REV. 12-28-11
 DATE: 12-22-11