



3"-150# R.F.S.O.
 FLG. W/ SCH. 40
 PIPE x 7" LG.
 (2) PLC'S.

NOTE: 1) HYDRO @ 197 PSIG. MIN.

HEADS / SHELL	.166" SA-414-G 2:1 S.E.	WL-653-B	REV. 9-12-06
	JOGGLE		DATE: 9-8-06
SHELL	.164" SA-414-G	FOR: VERT. CHILLED WATER TANK SURFACE AREA = 35.8 SQ. FT.	
		INSIDE: UNPAINTED	
M.A.W.P.	150 PSIG. @ 200 °F	OUTSIDE: PRIME	
M.D.M.T.	0 °F @ 150 PSIG.	LEG-ZONE 4-10 KM.	
ASME. SECTION VIII DIV. 1, 2004 ADD 2005		BY: E.S. / H.D. SCALE: 1" = 12"	
X-RAY:	RT-NO	ROY E. HANSON JR. MFG.	
GALLONS:	130	1600 E. WASHINGTON BLVD. LOS ANGELES, CA 90021	
WT.	327 LBS.		
SERIAL NO.			
N.B.			