

NOTE: 1) WELD 3/4"ø ROUND BARS TO SHELL AFTER HEADS ARE IN PLACE.
2) HYDRO @ 164 PSIG. MIN.

SHELL / HEADS	
.166" SA–414–G 2:1 S.E.	
JOGGLE	
.165" SA–414–G	
M.A.W.P. 125 PSIG. @ 200 °F	
M.D.M.T. 0 °F @ 125 PSIG.	
ASME. SECTION VIII DIV. 1, 2007 ADD 2007	
X–RAY: RT–NO	
GALLONS: 200 WT. 486 LBS.	
SERIAL NO.	
N.B.	

WM–225–B	REV.
FOR: –	DATE: 3–11–08
VERT. CHILLED WATER TANK	
SURFACE AREA = 51.0 SQ. FT.	
INSIDE: UNPAINTED	
OUTSIDE: SHOP PRIME	
BY: J.G. / C.J.	SCALE: 1"=12"

ROY E. HANSON JR. MFG.
1600 E. WASHINGTON BLVD.
LOS ANGELES, CA 90021