



5"-150# R.F.S.O.
FLG. W/ SCH. 40
SA-106-B
PIPE x 7 3/8" LG.
(2) PLC'S.

2" R W/ C.I. PLUG
INSP. OPENING
(2) PLC'S.

.136" THK. BAFFLE
PER: WN-170-B-1A

3/4" Ø ROUND BAR
SA-36 x 6" LG. (4) PLC'S.
SEE NOTE: 2

1/4" THK. CLIPS PER
MA-395-B (4) PLC'S.
W/ 9/16" Ø HOLE ON
26 3/8" B.C.; WELD OUTSIDE
VERT. EDGE OF CLIP ONLY

NOTE: 1) 2) WELD 3/4" Ø ROUND BARS TO SHELL AFTER HEADS ARE IN PLACE.
HYDRO @ 195 PSIG. MIN.

SHELL / HEADS		M.A.W.P. 150 PSIG. @ 200 °F		M.D.M.T. 0 °F @ 150 PSIG.		ASME SECTION VIII DIV. 1, 2010 ADD 2010		X-RAY: RT-NO		GALLONS: 250		WT. 563 LBS.		SERIAL NO.		N.B.	
.166" SA-414-F 2:1 S.E.		.175" SA-414-G															
JOGGLE		FOR: -		VERT. CHILLED WATER TANK		SURFACE AREA = 62.0 SQ. FT.		INSIDE: UNPAINTED		OUTSIDE: PRIME		BY: J.G./STEVE		SCALE: 1"=12"		REV. DATE: 2-16-11	
WN-170-B		WN-170-B		ROY E. HANSON JR. MFG.		1600 E. WASHINGTON BLVD. LOS ANGELES, CA 90021											

