



END VIEW W/OUT SUPPORTS

2) 4-1-04 PROOF TEST.
NOTE: 1) HYDRO @ 240 PSIG. MIN.

HEADS	.182" SA-455 2:1 S.E.	ES-36-335-H	REV. 9-15-04
	JOGGLE		DATE: 4-7-03
SHELL	.164" SA-414-G	FOR: HANSON STANDARD HORIZ. HOT WATER TANK	
		SURFACE AREA = 70.6 SQ. FT. INSIDE: EPOXY LINED	
M.A.W.P. 160 PSIG. @ 180 °F		OUTSIDE: PRIME	
ASME SECTION IV 2001 ADD. 2003		CAD-"B" UNDER "STD"-SERIES	
X-RAY: RT-NO/H.L.W.		BY: E.S.	SCALE: 3/4"=12"
GALLONS: 335 WT. 607 LBS.		ROY E. HANSON JR. MFG.	
SERIAL NO.		1924 COMPTON AVE. LOS ANGELES, CA 90011	