



- NOTE: 1) HYDRO @ 188 PSIG. MIN. TO 197 PSIG. MAX.  
 2) INSTALL (1) 1 5/16" x 30" LG. RIGID MAG. ANODE.  
 3) 4" PIPE SA-312-304 E.R.W.

HEADS		.164" SA-414-G 2:1 S.E.	
SHELL		.164" SA-414-G	
M.A.W.P.		125	PSIG. @ 210 °F
ASME SECTION IV		2007 ADD. 2009	
X-RAY:	RT-NO / H.L.W.		
GALLONS:	130	WT.	445 LBS.
SERIAL NO.			
N.B.			
FOR: -		REV.	7-13-10
HORIZ. HOT WATER TANK		DATE:	7-9-10
SURFACE AREA = 40.0 SQ. FT.			
INSIDE: GLASS LINED			
OUTSIDE: S. BLAST & PRIME			
BY: E.S. / C.J.		SCALE: 1"=12"	
<b>ROY E. HANSON JR. MFG.</b>			
1600 E. WASHINGTON BLVD.			
LOS ANGELES, CA 90021			

VIEW W/O SUPPORTS