



BUNDLE SUPT.
PER: WN-158-B-1A

- NOTE: 1) SEAL ALL OPENINGS TO KEEP CEMENT MOIST TO PREVENT CRACKING.
- 2) HYDRO @ 163 PSIG. MIN.
 - 3) EXTEND ALL CPLGS. 5/8" INSIDE.
 - 4) ALL FNPT ARE SA-182-304 S.S.
 - 5) B. & G. COLLAR SA-312-304 ERW S.S.

RIGHT - .289" SA-455	2:1 S.E.
LEFT - .250" SA-455	2:1 S.E.
HEADS	
(.272" MIN.)	
(.234" MIN.)	
.218" SA-455	
SHELL	
M.A.W.P.	125 PSIG. @ 210 °F
M.D.M.T.	-20 °F @ 125 PSIG.
ASME SECTION VIII DIV. 1, 2010 ADD. 2010	
X-RAY: RT-4 SPOT L.S. ONLY	
GALLONS:	1450 WT. 3111 LBS.
SERIAL NO.	
N.B.	

WN-158-B

FOR: -

HORIZ. HOT WATER TANK

182.5 SQ. FT. SURFACE AREA.
THIS TANK IS SHIPPED WITH ALL OPENINGS SEALED. THE CEMENT LINING MUST BE KEPT MOIST BEFORE, DURING, AND AFTER INSTALLATION TO PREVENT CRACKING OF THE CEMENT.

INSIDE: CEMENT LINED
OUTSIDE: SHOP PRIME

BY: J.G./C.J. SCALE: 1/2"=12"

ROY E. HANSON JR. MFG.

1600 E. WASHINGTON BLVD.
LOS ANGELES, CA 90021

VIEW W/OUT SUPT'S