



2) 8-26-04 PROOF TEST.
 NOTE: 1) HYDRO @ 225 PSIG. MIN. TO 235 PSIG. MAX.

SHELL / HEADS	.280" SA-455 2:1 S.E. (.210" MIN.)	ES-72-2150-V	REV. 9-9-04
			DATE: 9-25-89
		FOR: HANSON STANDARD VERT. HOT WATER TANK	
	.248" SA-455	SURFACE AREA = 232.0 SQ. FT. INSIDE: EPOXY LINED OUTSIDE: PRIME	
	M.A.W.P. 150 PSIG. @ 180 °F	LEG-ZONE 4-15 KM.	
	ASME. SECTION IV 2001 ADD 2003	CAD-"B" UNDER "STD"-SERIES	
	X-RAY: RT-NO / H.L.W.	BY: E.S.	SCALE: 1/2" = 12"
	GALLONS: 2150	WT. 2862 LBS.	ROY E. HANSON JR. MFG. 1924 COMPTON AVE. LOS ANGELES, CA 90011
	SERIAL NO.		
	N.B.		